

Project Owner:	Schoolcraft Community Schools
Project Name:	New Elementary Technology Systems
Issue Date:	July 29, 2022

ADDENDUM NO. 2

*This Addendum No. 2 of the **Technology Request for Bid** for the above referenced project hereby amends, supplements and/or augments all prior issued document(s) as described herein, and becomes an inseparable part of the Contract Documents, superseding all previous, contrary and/or conflicting information.*

AD2 - 1 Section 27 53 13.2.07.B.1 is hereby revised as follows:

1. Digital clock shall be Valcom VIP-440A or equal.

AD2 - 2 Section 27 53 13.2.08.B.1 is hereby revised as follows:

1. Digital clock shall be Valcom VIP-440ADS or equal.

AD2 - 3 Section 28 13 00.3.02.D.9 is hereby added as follows:

9. Work includes extending Ethernet from installed equipment, as required, to Owner identified connection outlets at all locations.
 - a. Work includes supply and connection of Category 6 Ethernet patch cables. Cables for some controllers may be in air plenum spaces, above finished ceilings, or in other ways require special care and suitable tools to complete.
 - b. Patch cables at controller location shall not exceed twenty-five (25) feet in length.
 - c. Patch cables at wire closets for cross connection to Owner's existing Ethernet switching infrastructure shall not be excessive in length, but be installed and routed to efficiently reach each connection point with reasonable and adequate slack for efficient "clean" access and ongoing maintenance.
 - d. Contractor shall cross connect and report back switch port locations back to Owner for programming as necessary.
 - e. Patch cables color shall be yellow in color.

END OF ADDENDUM NO. 2

<i>Bid ID: 2746</i>	Communications by Design, Inc.
<i>Addendum No. 2 Issued: August 17, 2022</i>	<i>Proprietary Information – All Rights Reserved</i>