

Project Owner:	Ludington Area School District
Project Name:	Secondary Complex Technology Renovations
Issue Date:	September 7, 2022

PROJECT QUESTIONS AND ANSWERS

*This document provides answers to questions asked by bidders who have reviewed the **Technology Request for Bid** for the above referenced project.*

Q1: One question for the music room. The spec indicates a Mackie mixer that only has two (2) XLR Inputs but three (3) microphones are requested. Please advise on the correct configuration needed for the mixer.

A: See addendum #2.

Q2: The drawing shows S1, S4 & S5 speakers. Spec book tells you a make-model for them. However there are also S2 & S3 speakers shown. Where can I find out what these speakers are for and what bid category?

A: S2 and S3 speaker types are identified in the Multimedia Systems bid category.

Q3: I have a question regarding the clock system out for bid at Ludington. The spec's state AND & Atlas IED are approved. However the spec also calls for the clocks to have multiple colored flashers. AND does not make that. So is AND an acceptable product or is it just the Atlas IED system you want quoted?

A: If there are no AND devices that meets all of the requirements specified then a AtlasIED device should be included in base bid proposal. Devices that do not meet all of the bid requirements should be included as a voluntary alternate for consideration.

END OF QUESTIONS AND ANSWERS #1

<i>Bid ID: 2722</i>	Communications by Design, Inc.
<i>Questions and Answers Issued: September 26, 2022</i>	<i>Proprietary Information – All Rights Reserved</i>