

ADDENDUM NO. 1

Project Owner:	Trenton Public Schools
Project Name:	District Technology Renovations
Issue Date:	August 7, 2023


This Addendum No. 1 of the Technology Request for Bid for the above referenced project hereby amends, supplements and/or augments all prior issued document(s) as described herein, and becomes an inseparable part of the Contract Documents, superseding all previous, contrary and/or conflicting information.

AD1 - 1	Appendix A: Building Diagrams is hereby revised, reissued and attached hereto.
AD1 - 2	<p>Section 28 20 00.2.05.3.a is hereby revised as follows:</p> <p>a. Interior/Outdoor High-Resolution Cameras (Type C)</p> <ul style="list-style-type: none">A. Axis M4327-P approved Axis or Hanwha Equal.B. Activity/motion detectionC. 0.16 lux, F2.2 minimum illumination (Color)D. 2160 x 2160 Image Size (6MP Resolution)E. H.264 CompressionF. Motion JPEG CompressionG. 60fps Frame Rate at 6MP resolutionH. 10/100 Ethernet (RJ-45) connectorI. IEEE power over Ethernet 802.3at complianceJ. Internal image memory for motion-based bufferingK. Operating temperature range from +32 – +104 degrees Fahrenheit.

END OF ADDENDUM NO. 1

<i>Bid ID: 3018</i>	Communications by Design, Inc.
<i>Addendum #1 Issued: August 21, 2023</i>	<i>Proprietary Information – All Rights Reserved</i>


Trenton High School First Floor



MDF i s in a small room inside the tech room next to the electrical
 IDF closet A is in a store room between the elevator and the main stairs
 IDF closet B is in a small store room inside of the science lab classrooms
 IDF C is in a small corner closet inside of the auto-tech classroom
 IDF F is in the Central Office Board Room in a small room off the north wall
 IDF G is in a small room inside of the TV Studio
 IDF H is in an equipment storage room by the gym
 IDF J is in a glass office room in the pool area


Trenton High School Second Floor

IDF D is upstairs above the Media Center
IDF E is upstairs between the main stairs and the elevator



MDF is located in the main office area in a small storage room
IDF closet 2 is in a storage room within the tech lab classroom
IDF closet 3 is in a small maintenance room by the gym

Arthurs Middle School First Floor




Arthurs Middle School Second Floor

IDF 1 is located on the west side upper level in a small workroom




Cameras

Arthurs Middle School (Lower) Loft A
6th grade level (basement)



Anderson Elementary School

MDF is in the custodial closet near the main office.
IDF closet B is in the custodial closet
IDF closet C is in the STEAM Lab
IDF Closet 2 is in the mechanical room near the gym



Hedke Elementary Second Floor

MDF is in the Kitchenette connected to the Staff Lounge
IDF closet B is across from the main office in the entry to small classrooms
IDF D is located in the gym storage room

