

Project Q & A

| | |
|-----------------------|-----------------------------|
| Project Owner: | East Lansing Public Schools |
| Project Name: | District Security Upgrades |
| Issue Date: | February 25, 2025 |

Project Questions and Answers:

This document provides answers to questions asked by bidders who have reviewed the Technology Request for Bid for the above referenced project.

| | |
|-----------|--|
| Q1 | Is the owner tied to Genetec? If not, would they be open to either the Hanwha Server, Digital Watchdog Spectrum or something like Exacqvision? |
| A1 | The Owner has expressed an interest in an integrated platform, in particular Genetec on their existing VM hardware. They are open to other options, and will carefully consider the details of all bids submitted. |
| Q2 | Is there a key that depicts each of the cameras and their model number |
| A2 | Yes. That information will be provided to the awarded bidder for installation activity as it was deemed not materially significant for bid preparation. |
| Q3 | Do all of the current Access Control points presently work? |
| A3 | Yes. |
| Q4 | For the new Administration Area and High School Addition I do not see a door hardware schedule with the model number of the Door Hardware to be provided. |
| A4 | Correct. That information is not yet available for the High School addition. See Addendum #1 for the current hardware schedule associated with the new administration building project. |
| Q5 | Who is responsible for the underground work that provides for cameras on your existing exterior poles? |
| A5 | No underground work is anticipated as existing cable connections that are currently in place will be reused for the new cameras. |
| Q6 | Are we to replace the cable to the existing exterior poles areas with CAT6A cable? |

| | |
|-----------|---|
| A6 | No. Please see specification Section 27 21 00.2.02 for detail. |
| Q7 | On New Cameras Drawing page 4 of 9 and page 7 of 9 look alike with the exception of 2 additional cameras. Is that correct? |
| A7 | See Addendum #1 which includes a new version of Appendix A without the duplicate sheet. |
| Q8 | If so I count 181 new camera locations but we are providing 200 cameras. We are missing 19 camera locations. |
| A8 | For the camera category of work, bidders are instructed to bid material and labor for complete installation based on the quantity of units listed in the specification document (Section 28 20 00.2.07.A.1 - 10). Building diagrams/maps/drawings may be adjusted slightly. |

Additional Note: During the prebid meeting, the representative reviewing the documents provided some limited incorrect information. The Owner does not want all cables replaced with Category 6a cable. The specification section listed herein clearly defines locations the Owner requires Category 6a cable. Existing cable in place that is working is expected to remain for any camera replacement. We are sorry about any confusion that this error may have caused. Please review Section 27 21 00.2.02 for correct detail of where Category 6a cable is required.

END OF QUESTIONS AND ANSWERS #1

| | |
|---|--|
| <i>Bid ID: 3064</i> | Communications by Design, Inc. |
| <i>Questions and Answers Issued: March 11, 2025</i> | <i>Proprietary Information – All Rights Reserved</i> |