

Project Q & A

Project Owner:	Western School District
Project Name:	Low Voltage Cabling
Issue Date:	December 1, 2023

Project Questions and Answers:

This document provides answers to questions asked by bidders who have reviewed the Technology Request for Bid for the above referenced project.

Q1	Are the cable tray and cabinets/racks provided and installed by others?
A1	Correct.
Q2	The drawings show a 2" sleeve in each room, are those provided and installed by others?
A2	Correct.
Q3	Is Hubbell an acceptable copper connectivity manufacturer.
A3	Yes, Western School District would consider Hubbell as an acceptable manufacturer.

END OF QUESTIONS AND ANSWERS #1